



No.C- 4997/2019

Office of the District Fire Officer
Fire and Rescue Services
Palakkad. Dated : 11.10.2019
Phone No.0491 2505702
E mail : adopkd.frs@kerala.gov.in

District Fire officer
Fire and Rescue Services
Palakkad.

The Principal
Darussalam English Medium School
Pullamkode
Karakurussi P.O.
Palakkad.


Sir,

Sub : Fire and Rescue Services, Palakkad – Returning of application for Fire
NOC reg.

- Ref: (1) G.O.(P) No.81/2017, 82/2017 of Local Self Government Department,
Dtd.31.10.2017.
- (2) Leter No.F2-9400/2016, dtd.16.04.2019 of Director General, Fire and
Rescue Services, Thiruvananthapuram.
- (3) Your Letter dated 05.10.2019.

Fire NOC is required only for those educational buildings having plinth area more than 1000m² or having height more than 15 meters vide the reference orders cited 1&2. Since this building won't come in these categories Fire NOC is not required and the application vide ref. (3) is hereby returned to the applicant. But you are instructed to install the fire protection system in the building as per existing rules and after its inspection we will issue a Fire Safety Certificate.

Yours faithfully


District Fire officer
Fire and Rescue Services
Palakkad

